

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 24/08/2026

It is certified that an inspection team headed by Venkatesh H.

Senior Analyst (Name of Officers with designation)

from Rural Drinking Water & Sanitation Division, Tumkur PHED

inspected the Venus International School, Chelur, Gubbi Taluk

(Name & Address of the school) on 24/08/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. TC-1484126000002286F

dated 25/08/2026 of Rural Drinking Water & Sanitation Division (PHED Lab)

certified that the

Venus International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 23/11/2026

Signature with Seal: Venkatesh H

Name : Venkatesh H

Designation : Senior Analyst (Jr)

Name & Address of the Office / Department : R.D.W. & S.D.

Water Testing Laboratory
Zilla Panchayath Building,
TUMAKURU - 572 101

To Venus International School
Chelur, Gubbi Taluk, Tumkur.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Tumkur District Water Quality Testing Laboratory
Zilla Panchayath Compound B.H Road Tumkur - 572101, Karnataka.
Email: rdwsd.wqmstp.tumkurdistrictlab@gmail.com

TC- 14841

TEST REPORT

Venus International School,
Chelur,
Gubbi Tq,
Tumkur District.

Name & Contact No: Darshan H.S. :7406562552

Sample Collected By: Customer
Reference: TRF
Sample code: TUM26AUG2286
ULR No: TC- 1484126000002286F
Date of Sample collection:24/08/2026
Sample receipt date: 24/08/2026
Analysis starts date: 25/08/2026
Analysis completion date: 25/08/2026
Report date: 25/08/2026
Sampling Method: APHA24th Edition
Sample quantity:1 Liter

Sample Particulars: Drinking Water

Sl. No	Test	Test Method	Detectable Limit	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500: 2012 RA-2018	Results	Units
Description: Colourless liquid.							
1.	pH Value at 25.2°C	IS 3025 (Part-11): 2022	2-14	6.5 – 8.5	No relaxation	6.58	-
2.	Electrical Conductivity, at 25.1°C	IS 3025 (Part-14) :2019	1.0	-	-	121	µS/cm
3.	Odour	IS 3025 (Part-5 & 6):2018	-	Agreeable	Agreeable	Agreeable	-
4	Taste	IS 3025 (Part-7 & 8):2023	-	Agreeable	Agreeable	-	-
5.	Colour	IS 3025 (Part-4) :2023	1	5	15	<1	H _z
6.	Turbidity	IS 3025 (Part-10): 2023	0.5	1	5	<0.5	NTU
7.	Total Dissolved Solids @ 180°C	IS 3025 (Part-16): 2023	16	500	2000	72	mg/l
8.	Alkalinity as CaCO ₃	IS 3025 (Part-23): 2023	20	200	600	28	mg/l
9.	Total Hardness as CaCO ₃	IS 3025 (Part-21): 2019	20	200	600	40	mg/l
10.	Calcium as Ca	IS 3025 (Part-40): 2024	8.0	75	200	13	mg/l
11.	Magnesium as Mg	IS 3025 (Part-46): ,2023	5.0	30	100	<5	mg/l
12	Chloride as Cl	IS 3025 (Part-32): 2019	10	250	1000	25	mg/l
13.	Sulphate as SO ₄	IS 3025 (Part-24/Sec 1): 2022	1.0	200	400	4.0	mg/l
14.	Fluoride as F, mg/l	APHA 24 th Edition 4500- F D	0.1	1	1.5	<0.1	mg/l
15.	Nitrate as NO ₃ , mg/l	APHA 24 th Edition 4500- NO ₃ B	1.0	45	No relaxation	8.3	mg/l
16.	Iron as Fe, mg/l	IS 3025 (Part-53): 2024	0.1	1	No relaxation	<0.1	mg/l

Reviewed & Authorized By

Venkatesh .H
Technical Manager

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 7 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

-: End of Report: -

R.D.W. & S.D.
Water Testing Laboratory
Zilla Panchayath Building,
TUMAKURU - 572 101